



False fuse for energy control



Testing fuse:
 Order No.: 49-6015-006
 Force-distance characteristic of
 the release pin
Spring colour: bright
Release force 48 N



Extension piece:
 Polyamide

Order no.:	"X" in mm	U_N in kV
49-6015-003	100	12
49-6015-004	175	17,5
49-6015-002	250	24

Comments : To measure the opening tripping blown fuse with minimum of energy : 0.5 Joule.